



NOTES:

1. CONTRACTOR SHALL USE INDUSTRIAL VACUUM SYSTEM WITH WATER JET TO EXPOSE AND LOCATE UTILITY.
2. CONTRACTOR SHALL BACKFILL WITH CONTROLLED DENSITY FILL (FLOWABLE FILL) IN ACCORDANCE WITH NYS DOT STANDARD SPECIFICATION 204.01 M CONTROLLED LOW STRENGTH MATERIAL TO WITHIN 90 mm OF THE SURFACE, THEN FINISH WITH 50 mm TYPE 3 ASPHALT BINDER AND 40 mm TYPE 7 ASPHALT TOP.

UTILITY WINDOW

NOT TO SCALE

2/2/04

REVISED